

Number	19-001157-PR01 (NW-K17-02-en-01)
Owner	Soudal N.V. Everdongenlaan 18-20 2300 Turnhout Belgium
Product	Window sealing tape
Designation	SWS Inside Extra (item 145967) SWS Outside Extra (item 145968)
Details	manufacturer Soudal N.V.; material: Non-woven and functional layer synthetic PP fleece, full-surface self-adhesive with acrylic dispersion; tested glueing width: 10mm; tested joint width: 20 mm
Special features	SWS Inside Extra: suitable for interior applications only SWS Outside Extra: suitable for exterior applications only

Result

Air permeability according to EN 12114:2000-03



Air permeability in new condition $a < = 0,1 \text{ m}^3/(\text{m}^*\text{h}*\text{daPa Exp } 2/3)$

Watertightness based on EN 1027:2016-03



No water penetration until = 600 Pascal

Basis *)

Test report: 19-001157-PR01 PB-K17-02-de-01

Representation



Instructions for use

Testing of the product was determined in an "ideal" joint and in new condition based on DIN 18542, Clause 8.2 and 8.3. The results of the tested performance characteristics cannot be used as evidence of linear joints performed in practice.

Validity

There is no time limit. When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

The data and results given relate solely to the tested/described specimen.

This test does not allow any statement to be made on further characteristics of the present structure regarding performance and quality, in particular the effects of weathering and ageing.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies. The cover sheet can be used as abstract.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: E46-85F1D

ift Rosenheim
20.12.2019



Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing



Martin Heßler, Dipl.-Ing. (FH)
Project Engineer
Building Component Testing